

ADDENDUM NUMBER: THREE

PROJECT: Nash County Med Park Building Renovations
500 Nash Medical Arts Mall
Rocky Mount, North Carolina
Project Number 23048A

DATE: June 23, 2025

OWNER: Nash County
120 W. Washington Street
Nashville, North Carolina 27804

ARCHITECT: Oakley Collier Architects, PA
109 Candlewood Road
Rocky Mount, North Carolina 27804

PREVIOUSLY ISSUED: Two

TO ALL CONTRACTORS:

This Addendum is hereby made a part of the Contract Documents to the same extent as if originally included therein. This Addendum must be acknowledged on the Form of Proposal and shall be placed with the Contract Documents.

Drawings dated June 4, 2025, and Project Manual dated June 2025 for this project are hereby modified, corrected, or supplemented as follows:

General

Item 1 Change: **Pre-Bid Sign-In**
Please correct Damon Jones of JM Thompson's phone number to read "(919) 922-7568"

Specifications

Item 1 Delete **Section 02 41 00 Demolition**
Delete 3.05 D, item 1 which reads:
~~1. Remove rotted wood, corroded metals, and deteriorated masonry and concrete; replace with new construction indicated.~~

Item 2 Delete **Section 09 65 19 Resilient Tile Flooring**
Replace specification section 09 65 19 in its entirety with the attached.

Drawings

Item 1 Add: **Sheet P0.1 – Plumbing Fixture Schedule**
Replace sheet P0.1 in its entirety with the attached. Fixture BP-1, Backflow Preventer has been added to the schedule.

Item 2 Change:

Sheet P1.2 – Plumbing Water Plan

Replace sheet P1.2 in its entirety with the attached. The plan has been revised to clearly indicate new versus existing water piping. Valves are now shown in new water piping branch lines. New valving in existing branch lines or at individual fixtures are not shown. A backflow preventer, BP-1, has been added to Janitor's Closet 223 (between Men 222 & Women 226). These changes are in response to the City of Rocky Mount plan review.

Item 3 Change:

Sheet P2.1 – Plumbing Waste Riser

Replace sheet P2.1 in its entirety with the attached. This sheet has been correctly labeled as Plumbing Waste Riser to address a plan review comment.

Item 4 Add:

Sheet P2.2 – Plumbing Water Riser

Add the attached sheet P2.2 – Plumbing Water Riser.

End of Addendum