

ITB # 26-408 Hampstead Library Construction Services

Addendum 2

December 9, 2025

To: All Plan Holders

From: Scott Spike



General Items

1. Bid date and time remain unchanged.

Specification Items

1. Section 04 2000 – Unit Masonry: Revise paragraph **1.06-B** to read as follows:
Company specializing in performing work of the type specified and with at least five years of documented experience on projects of a similar size and scope to this project, and a current member of MCAA or NCMCA.
2. Section 07 1300 – Sheet Waterproofing: Revise paragraph **2.01-A-4-a** to change product from Preprufe 800PA to Bituthene 3000.
3. Section 09 5100 – Acoustical Ceilings:
 - a. Revise paragraph **2.01-A** to read:
 - A. Acoustic Tiles/Panels:
 1. Armstrong World Industries, Inc.: www.armstrongceilings.com/#sle.
 - a. White: Ultima High NRC 2081
 - b. Color: Calla 2822
 2. Certainteed Architectural: www.certainteed.com/ceilings-and-walls/#sle.
 - a. White: Symphony m High NRC 1222BB-85-1
 - b. Color: Ecophon Focus E 3542 2263
 3. USG Corporation: www.usg.com/ceilings/#sle.
 - a. White and Color: Mars High-NRC 88135
 4. Substitutions: See Section 01 6000 – Product Requirements.
 - b. Revise paragraph **2.01-B** to read:
 - B. Suspension Systems:
 1. Armstrong World Industries, Inc.; Prelude XL 15/16 inch: www.armstrongceilings.com/#sle.
 2. Certainteed Architectural; 15/16 EZ Stab Classic System: www.certainteed.com/ceilings-and-walls/#sle.
 3. USG Corporation; Donn Brand DX 15/16: www.usg.com/ceilings/#sle.
 4. Substitutions: See Section 01 6000 – Product Requirements.
 - c. Revise paragraph **2.02-B-8-b** to read: Custom color ceiling tiles; allow for up to four custom colors, up to a total of 1200 square feet.
 - d. Revise paragraph **2.03-B-3-b** to read: Custom color painted caps; allow for up to four custom colors, up to a total of 1200 square feet.
 - e. Paragraph **2.03-B-4** is deleted.

Pender County Library, Hampstead Branch

Addendum 2

- f. Revise paragraph **2.04-D-3** to read: Custom color perimeter moldings; allow for up to three custom colors.
- 4. Section 09 8430 – Sound-Absorbing Wall and Ceiling Units: Revise paragraph **2.01-C-2-a** to read as follows:
 - Ceilings: Nominal panel size 4 feet wide by 8 feet long. Butt panels together and provide custom length units at ends to provide overall panel lengths indicated on drawings – field verify overall length required. Unless noted otherwise, custom length units shall not be less than 4 feet long.
- 5. Section 13 3400 – Fabricated Engineered Structures: Revise paragraph **2.01-A-1** to read as follows:
 - Basis of Design Manufacturer – Canopies, Custom Shade Panels, and Support Structures: Poligon, Porter Corp. a PlayCore Company; www.portercorp.com. (Brad Fritz: brad.fritz@portercorp.com)
- 6. Section 27 1500 – Communications Horizontal Cabling:
 - a. Paragraph **2.3** is replaced with the following:
 - 2.3 UTP CABLE
 - A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. Belden Inc.
 - 2. Berk-Tek; a Leviton company.
 - 3. CommScope, Inc.
 - 4. Draka, a Prysmian Brand.
 - 5. Genesis Cable Products; Honeywell International, Inc.
 - 6. Mohawk; a division of Belden, Inc.
 - 7. Molex Premise Networks; a division of Molex, Inc.
 - 8. Superior Essex Inc.
 - 9. SYSTIMAX; a CommScope, Inc. brand.
 - 10. 3M.
 - b. Paragraph **2.4** is replaced with the following:
 - 2.4 UTP CABLE HARDWARE
 - A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. American Technology Systems Industries, Inc.
 - 2. Belden, Inc.
 - 3. CommScope, Inc.
 - 4. Dynacom Corporation.
 - 5. Hubbell Premise Wiring.
 - 6. Leviton Voice & Data Division.
 - 7. Molex Premise Networks; a division of Molex, Inc.
 - 8. Panduit Corp.
 - 9. Siemon Co.
 - c. Revise paragraph **2.4-E** to read as follows:

Pender County Library, Hampstead Branch

Addendum 2

- E. Patch Cords: Factory-made, four-pair cables; terminated with eight-position modular plug at each end.
 1. Patch cords shall have bend-relief-compliant boots and color-coded icons to ensure Category 6 performance. Patch cords shall have latch guards to protect against snagging.
 2. Data Room: Provide one patch cord for each cable terminated. 50% shall be 2' in length, and 50% shall be 4' in length.
 3. Outlets: Provide one patch cord for each cable terminated. 50% shall be 6' in length, 25% shall be 4' in length, and 25% shall be 10' in length.

Drawing Items

1. Sheet A6.0 Schedules & Door Elevations: For rooms 106 Meeting and 110 Multipurpose Room, revise the Remarks to read, "PT wainscot at sink – See sheets A7.3 and A7.4 for extents; Wall Protection up to 4'-0" AFF – See Sheet A7.5 for extents; Roller Shades at windows."

Clarifications

1. Where the drawings refer to "wall protection", please see Section 10 2600 Wall and Door Protection for the specified materials.

Approved Substitutions

The following manufacturers have been reviewed and accepted:

1. Section 07 1300 – Sheet Waterproofing:
 - GMX Inc.; TegoBloc SA: www.gmxco.com
 - Soprema; Colphene 3000: www.soprema.us
2. Section 08 4229 – Automatic Entrances:
 - Horton Automatics: www.hortondoors.com
3. Section 08 9200 – Louvered Equipment Enclosures:
 - ModWerks, a division of HTS; Linea: www.lineascreen.com

End of Addendum 2