

# Hite associates

ARCHITECTURE / PLANNING / TECHNOLOGY

## ADDENDUM NO. 2

September 14, 2023

Project: **Community Center & Gymnasium for Alice Keen District Park**  
**Pitt County, North Carolina**

**TO: ALL BIDDERS**

*The following items clarify, add to, delete from, and / or otherwise change and supersede information previously issued to you in the bidding documents for the referenced project. Please read them carefully and adjust your bid accordingly.*

*Please note that addendums, and all revised documents are available via Hite Associates website [www.hiteassoc.com](http://www.hiteassoc.com) under the "Contractor Resources" link.*

### ADDENDUM NO. 2:

1. Drawing C-100 Demolition Plan: Added curb cut for new ADA Concrete Ramp at entrance drive.
2. Drawing C-101 Geometry Plan: Added new 8'-0" wide Asphalt Pathway to new south drive entrance from existing path with new ADA Curb Cut at main Drive and cross walk with truncated dome pads. Detail C-101.4.
3. Drawing C-102 Geometry Plan: Continuation of new 8'-0" wide Asphalt Pathway to new south drive entrance from existing path, with painted Crosswalk and ADA Concrete access with truncated dome pads; Detail C-102.3.
4. Drawing C-202 Erosion Control: Revised to suit Geometry Plan Sheets. New Silt Fence added along new asphalt Pathway.
5. Drawing C-203 Erosion Control: Revised to suit Geometry Plan Sheets. New Silt Fence added along new asphalt Pathway. Revised Drainage Swale north side of south drive.
6. Drawing C-204 Grading Plan: Revised to suit Geometry Plan Sheets
7. Drawing C-205 Grading Plan: Revised to suit Geometry Plan Sheets. New 15" RCP drainage pipe added below new asphalt path. Revised Drainage Swale north side of south drive.
8. Drawing L-101 Landscape Plan: Revised to suit Geometry Plan Sheets.
9. Clarification: The Fire Pump Controller is the Auto-Trans-Sw (ATS) for that equipment.
10. Drawing PME-001: Revised Fire Pump Riser to eliminate disconnect sw.

*COMMUNITY CENTER & GYMNASIUM FOR ALICE KEENE DISTRICT PARK*

11. Drawing M-001: Revised Gas Pack Schedule Notes to coordinate with plan notes.
12. Drawing E-001: Revised Electrical Riser Diagram to add panel FS and associated feeders.
13. Drawing E-101A: Revised panel MDP schedule to show breaker for panel "FP".

END OF ADDENDUM NO. 2



---

James G. Hite, AIA, Project Architect  
Hite Associates, PC

BIDDERS PLEASE NOTE THAT REFERENCED REVISED DOCUMENTS AND DRAWING REVISIONS ARE MARKED AS SUCH ON THE REVISION BLOCK ON THE PLANS AND ARE TO BE ACCESSED ON THE HITE ASSOCIATES WEBSITE.

Revised / Added Documents:

Drawing C-100  
Drawing C-101  
Drawing C-102  
Drawing C-202  
Drawing C-203  
Drawing C-204  
Drawing C-205  
Drawing L-101  
Drawing PME-001  
Drawing M-001  
Drawing E-001  
Drawing E-101A

cc: All Attendees / All Bidders / Tim Corley / Austin Long

dist.: JGH / RBE / TS / WP / File: Bids & Addenda