

RELATED DOCUMENTS:

The general provisions of the Contract, including General and Supplementary Conditions, and General Requirements, and Division 1 specifications that apply to the work specified in this Section.

PART 1 - GENERAL

DESCRIPTION OF WORK:

Furnish and install the following:

1. Stainless Steel Corner Guards
2. Stainless Steel End Wall Protector
3. Stainless Steel Column Covers

RELATED SECTIONS

Section 05400 - Cold-Formed Metal Framing System
Section 09250 – Gypsum Drywall Systems
Section 09260 – Gypsum Drywall Framing
Section 09300 - Tile

QUALITY ASSURANCE:

Manufacturers:

Standard: For purposes of designating type and quality for work under this Section, Drawings and Specifications are based on products manufactured or furnished by Manufacturers listed with products.

SUBMITTALS:

Manufacturer's Data: Submit for approval three (3) copies of folder containing complete Manufacturer's data and installation procedures for all items to be furnished in work of this Section of Specifications.

Shop Drawings: Submit for each specialty item specified in accordance with General Conditions.

PART 2 - PRODUCTS

MATERIALS:

1. Corner Guards: Provide Stainless Steel Flush Mount Corner Guard, full height 90-degree corner guards with 3" double exposure, Model SSEW-FM, as manufactured by InPro Corporation, or equivalent products by CS Group.

Provide full floor-to-ceiling height corner guards at outside corners, as indicated on Drawings.

Exposed face of corner guard, stainless steel satin finish material with wall thickness of at least .060 inch thick, 1/8" radius corners, manufactured from Type 430, 16 gauge stainless steel.

Finish: No. 4 satin finish

Attached with manufacturer's Phillips head screw fasteners through pre-drilled beveled holes.

DIVISION 10
SECTION 10850

SPECIALTIES
MISCELLANEOUS SPECIALTIES

Furnish Architect one 6" sample complete with selected color for approval.

2. End Wall Protector: Provide Stainless Steel Flush Mount End Wall Protector for wall protection, full height wall protectors with 3 1/8" double exposure x custom width, Model SSEW-FM, as manufactured by InPro Corporation, or equivalent products by CS Group.

Provide full floor-to-ceiling height corner guards at outside corners, as indicated on Drawings.

Exposed face of end protector, stainless steel satin finish material with wall thickness of at least .060 inch thick, 1/8" radius corners, manufactured from Type 430, 16 gauge stainless steel.

Finish: No. 4 satin finish

Attached with manufacturer's Phillips head screw fasteners through pre-drilled beveled holes.

Furnish Architect one 6" sample complete with selected color for approval.

3. 24" Stainless Steel Column Cover: Provide Model E Column Cover by Frye Reglet, or equivalent products by AmeriClad or MOZ Designs. Round 24" diameter, satin stainless steel finish, complete assembly with internal concealed structural bracing with vertical attachment posts, and post foot tops and bottoms. Provide hairline butt joint EX splice Series "E" attachment spring clips.

Provide 4" high x 3/4" deep reveal toe space at floor with matching closure, material matching cover skin material.

Provide Fry Reglet Wall Angle Column Ring with taping flange for drywall ceiling termination/transition.

PART 3 - EXECUTION

INSTALLATION:

Install products in strict accordance with manufacturer's printed instructions. General Contractor shall coordinate requirements by other prime contractors.

END OF SECTION