



001.1 ROOF AND ROOF DRAINAGE PLAN
SCALE: 1/16" = 1'-0"

- 1) CM WALLS WHERE INDICATED SHALL BE RUN SOLD TO BOTTOM OF FOUNDATION. ALL OTHER WALLS SHALL BE RUN TO FULL BLOCK COURSE ABOVE CEILING. UNBARRED SECTIONS OF LESS-THAN-FULL BLOCK WALLS SHALL BE REINFORCED WITH STEEL STRUCTURAL SHAPES.
- 2) CM WALL INTERSECTIONS SHALL BE BONDED WITH HOT REFINED GALVANIZED HORIZONTAL PREFORMED 1" HORIZONTAL REINFORCED EMBEDDED AT 16" ON CENTER.
- 3) PROVIDE WALL CONTROL AND EXPANSION JOINTS WHERE SHOWN AND DETAIL OR IN PRE-APPROVED JOINT SCHEDULE. PROVIDE JOINTS 2" OR MORE FROM CORNERS AND ALL OTHERS IN MASONRY WALLS; BOTH SIDES IN OPENINGS WITH WALL EXCEEDING 5'-0" SEE DETAIL.
- 4) PROVIDE WALL EXPANSION JOINTS AT POINTS AND INTERSECTIONS WHERE INDICATED, OR UNBARRELLED WITH EXPANSION JOINT MATERIAL, AND GASKS, WITH BACKER ROD EACH EXPOSED SIDE.
- 5) ALL 90° OUTSIDE CM CORNERS SHALL HAVE BULLNOSE EDGE UG.
- 6) INTERIOR CM JOINTS SHALL BE:
 - a) ALL CM SURFACES TO RECEIVE PAINT OR PLASTER SHALL BE POINTED UP AND PATCHED WITH MORTAR TO ELIMINATE DEPRESSIONS, VOIDS OR OTHER IRREGULARITIES.
 - b) MORE THAN 1/4" DIAMETER INTERIOR WALL CORNERS SHALL BE ROUNDED TO MINIMUM 1/4" DIAMETER AFTER APPLICATION OF BLOCK FILLER BLOCK FILLER SHALL BE MINIMUM 1" THICKNESS AND REINFORCED TO ELIMINATE CRACKING. PROVIDE 1/2" PHOLES IN MASONRY SURFACES. FIRST PAINT SHALL BE SPRAY APPLIED, & ROLLED IN.
- 7) LAY-IN ACoustICAL TILE CEILING SYSTEM SHALL BE 2' x 2' x 0.75" IN LAYING OUT BUILDING COORDINATE, COORDINATE LIGHTING AND ELECTRICAL DRAWINGS, AND AVOID USE OF LESS-THAN-HAFT SIZE UNITS.
- 8) PROVIDE EXTERIOR CONCRETE WALLS AND CONCRETE AREAS WITH EXPANSION AND SCORED JOINTS TO MATCH INTERIOR WALLS. PROVIDE JOINTS TO MATCH INTERIOR WALLS. ALL TOOLS TO 1/4" RAD AND FILL WITH HOT RUBBER ASPHALT SEALANT - PROVIDE AT ALL INTERIOR WALL CHANGES, CORNERS, AND INTERSECTIONS. PROVIDE JOINTS IN WALLS OR PAVEMENTS, AND AT INTERVALS NOT TO EXCEED 30'. SCORED JOINTS SHALL BE SCORED TO DEEP MINIMUM AND RADUSED 1/4". WALLS SHALL BE PLACED AT INTERVALS NOT TO EXCEED 5 FEET.
- 9) GENERAL CONTRACTOR SHALL COVER CASEWORK, BUILT-INS AND ACCESSORIES LOCATIONS WITH OTHER TRADES.

(1) CONSTRUCT SAMPLE $4' \times 4'$ WALL PANEL WITH INSULATION IN PLACE, SHOWING EXTERIOR BRICK AND INTERIOR BLOCK WORKMANSHIP. APPROVED PANEL WILL BE USED AS STANDARD OF QUALITY THROUGHOUT.

(2) COMPLETE CONSTRUCTION OF ONE EACH OF THE FOLLOWING IS REQUIRED FOR ARCHITECT'S APPROVAL. APPROVED CONSTRUCTION IN EACH CASE WILL BE USED AS STANDARD OF QUALITY REQUIRED THROUGHOUT.

- A. WINDOW SECTION, FITTED AND CAULKED.
- B. ROOF OVERHANG WITH GUTTER.
- C. ROOF COPING SECTIONS (2 WITH GUTTER).
- D. CLASSROOM: CARPET, RUBBER BASE, PAINTING/STAINING, MARKERBOARDS AND TACKBOARDS, CEILING.

(3) SEE SPECIFICATIONS FOR ALLOWABLE CONSTRUCTION TOLERANCES. THESE WILL BE CHECKED AND ENFORCED.

